

CERTIFICATE

Issued to:

Applicant:

MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Wukang Town,
Deqing County,
313200 Zhejiang Province, P.R., China

Licensee:

MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Wukang Town,
Deqing County,
313200 Zhejiang Province, P.R., China

Product : Moulded-Case Circuit-Breaker
Trade name(s) : MAXGE
Type(s)/model(s) : SGM3S-250L and SGM3S-250M

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-2:2017
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2165673

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 7 December 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 33-106332

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



H.R.M. Barends
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT

Product data

Product	: Moulded-Case Circuit-Breaker
Trade name(s)	: MAXGE
Type(s)/model(s)	: SGM3S-250L and SGM3S-250M
Number of poles	: 3P and 4P (unprotected N pole)
Protected pole	: 3
Rated operational voltage (Ue)	: 380 Vac / 400 Vac / 415 Vac
Rated insulation voltage (Ui)	: 800 V
Rated impulse withstand voltage (Uimp)	: 8 kV
Rated frequency	: 50 / 60 Hz
Rated current (In)	: 100 A, 125 A, 140 A, 150 A, 160 A, 175 A, 180 A, 200 A, 225 A, 250 A
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: Equal to In
Suitable for isolation	: Suitable
Selectivity category	: A
Safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 50 mm, Up / Down: 50 mm
Reference temperature	: 40 °C and 55 °C
Ambient temperature	: - 5 °C to 40 °C for reference temperature 40 °C - 5 °C to 40 °C and 55 °C for reference temperature 55 °C
Method of mounting	: Fixed
EMC environment	: A and B
Tightening torque for terminals	: 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Thermal type, Ir = 0,8 In - 1,0 In
Time setting of the inverse time delay release	: Fixed, trip time at 2 In: 2 min ≤ t ≤ 12 min
Instantaneous release	: Magnetic type, fixed, 2 poles in series: li = 10 In single pole: 12 In

Product data – type SGM3S-250L

Rated service short-circuit breaking capacity (Ics)	: 27 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 36 kA

Product data – type SGM3S-250M

Rated service short-circuit breaking capacity (Ics)	: 36kA
Rated ultimate short-circuit breaking capacity (Icu)	: 50 kA

TESTS

Test requirements

EN 60947-2:2017

Test result

The test results are laid down in DEKRA test file 331485800.

Additional information

Nomenclature breakdown:

SGM3S-250M/4300

a b c d

a = Model name: SGM3S

b = Frame size: 250

c = short-circuit capacity: 'M' or 'L'

d = pole numbers, '4' means 4P MCCBs, '3' means 3P MCCBs

The referred test report is 3314858.50.

The product also complies with IEC 60947-2:2016.

This certificate replaces certificate No. 3306229.01 which we herewith declare invalid.

Conclusion

The examination proved that all requirements were met.

Factory location

MAXGE ELECTRIC TECHNOLOGY CO., LTD.

No.299 East Changhong Road, Wukang Town, Deqing County,
313200 Zhejiang Province, P.R., China