

ATTESTATION OF CONFORMITY

Issued to: MAXGE ELECTRIC TECHNOLOGY CO., LTD
No.299 East Changhong Road, Wukang Town
313200 Deqing County, Zhejiang, China

For the product: Moulded-Case Circuit-Breaker

Trade name: GEBLER or GEMAX

Type/Model: SGM6E-630M, SGM6E-400M, SGM6E-630H, SGM6E-400H, iSGM6E-630M,
iSGM6E-400M, iSGM6E-630H, iSGM6E-400H

Ratings: Ue: 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz
Ui: 1000 V, Uimp: 8 kV
In: 250 A, 300 A, 315 A, 320 A, 400 A, 500 A, 600 A, 630 A
3P and 4P (N pole without overcurrent protection)
See annex for further ratings

Manufactured by: MAXGE ELECTRIC TECHNOLOGY CO., LTD
No.299 East Changhong Road, Wukang Town
313200 Deqing County, Zhejiang, China

Subject: Complete evaluation of electrical system of the appliances

Requirements: EN 60947-2:2017, EN 60947-2:2017/A1:2020, IEC 60947-2:2016,
IEC 60947-2:2016/AMD1:2019

Remark: This Attestation is based on AoC no. 3332392.01-AOC issued on 2024-11-04.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in test report no 3332396.50 issued on 2025-05-20.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This document does not authorize the use of any DEKRA approved mark.

Wenzhou, Zhejiang, 23 May 2025

Number: 3332396.01-AOC

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing Services (Zhejiang) Co., Ltd

No. 5. Changjiang Road, Great Bridge Industrial Park, North Baixiang, Wenzhou, 325603 Zhejiang, China
T +86 57762 868000 www.dekra-product-safety.com

Ratings:

Number of poles	: 3P and 4P (N pole without overcurrent protection)
Rated operational voltage (Ue)	: 380 Vac / 400 Vac / 415 Vac
Rated insulation voltage (Ui)	: 1000 V
Rated impulse withstand voltage (Uimp)	: 8 kV
Rated frequency	: 50 / 60 Hz
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: Equal to In
Rated short-time withstand current (Icw)	: 8 kA - 1 s
Individual pole short-circuit (Irr)	: 12 In
Suitable for isolation	: Suitable
Selectivity category	: B
Safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 100 mm, Up / Down: 100 mm
Reference temperature	: Independent
Method of mounting	: Fixed
EMC environment	: A and B
Tightening torque for terminals	: M10 / 10 Nm
Line/load terminal Connection	: Marked Copper conductor with cable lug for 250 A and 400 A, copper conductor with cable lug or copper busbar with (40 x 5) mm ² x 2 for 630 A

Product rating - iSGM6E-630H

Rated current (In)	: 250 A, 300 A, 315 A, 320 A, 400 A, 500 A, 600 A, 630 A
Rated service short-circuit breaking capacity (Ics)	: 75 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 100 kA / 75 kA
Inverse time delay release	: Ir: (0,4-1,0) x In, in step of 1 A
Time setting of the inverse time delay release	: tr: 12 - 150 s at 2 Ir + OFF, in step of 1s, with tolerance of $\pm 10\%$ tripping time at 2 Ir: 12 s $\pm 10\%$ (tr = 12 s) 150 s $\pm 10\%$ (tr = 150 s)
Short time delay release	: Isd: (2 - 12) x Ir, in step of 1A
Time setting of the short time delay release	: Isd: 0,06 - 1,0 s + OFF, in step of 0,01s, with tolerance of $\pm 10\%$ (min. 40 ms) non-tripping duration: Set at 0,06 s: 0,02 s, Set at 1,0 s: 0,9 s
Instantaneous release	: Ii: (4 - 14) x Ir + OFF, in step of 1 A
Ground fault release	: Ig: (0,2 - 1,0) x In + OFF, in step of 1 A (only for 4P) tg: 0,4 - 1 s, in step of 0,1 s, with tolerance of $\pm 10\%$

Product rating - iSGM6E-400H

Rated current (In)	: 250 A, 300 A, 315 A, 320 A, 400 A
Rated service short-circuit breaking capacity (Ics)	: 75 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 100 kA / 75 kA
Inverse time delay release	: Ir: (0,4-1,0) x In, in step of 1 A
Time setting of the inverse time delay release	: tr: 12 - 150 s at 2 Ir + OFF, in step of 1s, with tolerance of $\pm 10\%$ tripping time at 2 Ir: 12 s $\pm 10\%$ (tr = 12 s) 150 s $\pm 10\%$ (tr = 150 s)
Short time delay release	: Isd: (2 - 12) x Ir, in step of 1A
Time setting of the short time delay release	: tsd: 0,06 - 1,0 s + OFF, in step of 0,01s, with tolerance of $\pm 10\%$ (min. 40 ms) non-tripping duration: Set at 0,06 s: 0,02 s, Set at 1,0 s: 0,9 s
Instantaneous release	: Ii: (4 - 14) x Ir + OFF, in step of 1 A
Ground fault release	: Ig: (0,2 - 1,0) x In + OFF, in step of 1 A (only for 4P) tg: 0,4 - 1 s, in step of 0,1 s, with tolerance of $\pm 10\%$

Product rating - iSGM6E-630M

Rated current (In)	: 250 A, 300 A, 315 A, 320 A, 400 A, 500 A, 600 A, 630 A
Rated service short-circuit breaking capacity (Ics)	: 60 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 60 kA / 85 kA
Inverse time delay release	: Ir: (0,4-1,0) x In, in step of 1 A
Time setting of the inverse time delay release	: tr: 12 - 150 s at 2 Ir + OFF, in step of 1s, with tolerance of $\pm 10\%$ tripping time at 2 Ir: 12 s $\pm 10\%$ (tr = 12 s) 150 s $\pm 10\%$ (tr = 150 s)
Short time delay release	: Isd: (2 - 12) x Ir, in step of 1A
Time setting of the short time delay release	: tsd: 0,06 - 1,0 s + OFF, in step of 0,01s, with tolerance of $\pm 10\%$ (min. 40 ms) non-tripping duration: Set at 0,06 s: 0,02 s, Set at 1,0 s: 0,9 s
Instantaneous release	: Ii: (4 - 14) x Ir + OFF, in step of 1 A
Ground fault release	: Ig: (0,2 - 1,0) x In + OFF, in step of 1 A (only for 4P) tg: 0,4 - 1 s, in step of 0,1 s, with tolerance of $\pm 10\%$