

ATTESTATION OF CONFORMITY

Issued to: MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Wukang Town, 313200 Deqing County,
Zhejiang, China

For the product: Moulded-Case Circuit-Breaker

Trade name: MAXGE

Type/Model: SGM6-250C, SGM6-250H, SGM6-250L, SGM6-250M,
SGM6s-250H, SGM6s-250L, SGM6s-250M,
SGM6sm-250H, SGM6sm-250L and SGM6sm-250M

Ratings: Ue: 380 Vac / 400 Vac / 415 Vac, 50 / 60 Hz
Ui: 1000 V, Uimp: 8 kV
In: 100 A, 125 A, 140 A, 150 A, 160 A, 175 A, 180 A, 200 A, 225 A, 250 A
3P and 4P (N pole without overcurrent protection)
See annex for further ratings

Manufactured by: MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No.299 East Changhong Road, Wukang Town, 313200 Deqing County,
Zhejiang, China

Subject: Type test

Requirements: EN 60947-2:2017, EN 60947-2:2017/A1:2020,
IEC 60947-2:2016, IEC 60947-2:2016/A1:2019

Remark: This Attestation replaces AoC no. 3322102.01A issued on 2022-02-10.

This Attestation is granted on account of an examination by DEKRA, the results of which are laid down in a test report no 3320695.50 issued on 2023-05-09.

This Attestation implies that the examined types are in accordance with the standards designated under the Low voltage directive (LVD) 2014/35/EU.

The examination has been carried out on one single specimen or several specimens of the product, submitted by the manufacturer. The Attestation does not include an assessment of the manufacturer's production. Conformity of his production with the specimen tested by DEKRA is not the responsibility of DEKRA.

The CE marking may be affixed on the product if all relevant and effective EC directives are complied with.

Wenzhou, Zhejiang, 14 June 2023

Number: 3326095.01-AOC

DEKRA Testing Services (Zhejiang) Co., Ltd

Ms J Guo
Certification Manager

© Integral publication of this attestation and adjoining reports is allowed

DEKRA Testing Services (Zhejiang) Co., Ltd
No. 5. Changjiang Road, Great Bridge Industrial Park, North Baixiang, Wenzhou, 325603 Zhejiang, ZJ, China
T +86 57762 868000 F +86 57762 919889 www.dekra-product-safety.com



Ratings:

Number of poles	: 3P and 4P (N pole without overcurrent protection)
Rated operational voltage (Ue)	: 380 Vac / 400 Vac / 415 Vac
Rated insulation voltage (Ui)	: 1000 V
Rated impulse withstand voltage (Uimp)	: 8 kV
Rated frequency	: 50 / 60 Hz
Rated current (In)	: 100 A, 125 A, 140 A, 150 A, 160 A, 175 A, 180 A, 200 A, 225 A, 250 A
Conventional thermal current (Ith)	: Equal to In
Current rating for four-pole circuit-breakers	: Equal to In
Individual pole short-circuit (IIT)	: 12 In
Suitable for isolation	: Suitable
Selectivity category	: A
Safety distance (screen-circuit breaker)	: Front / Back: 0 mm, Left / Right: 50 mm, Up / Down: 50 mm
Reference temperature	: 40 °C or 55 °C
Ambient temperature	: - 5 °C to 40 °C for reference temperature 40 °C - 5 °C to 40 °C and 55 °C for reference temperature 55 °C
Method of mounting	: Fixed
EMC environment	: A and B

Product rating - SGM6sm-250H

Rated service short-circuit breaking capacity (Ics)	: 50 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 65 kA / 50 kA
Tightening torque for terminals	: M8 / 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Ir: (0,8, 0,9, 1,0) x In or (0,7, 0,85, 1,0) x In
Time setting of the inverse time delay release	: Fixed, tripping time at 2 Ir: 30 s - 11 min
Instantaneous release	: Ii: (5, 6, 7, 8, 9, 10) x In

Product rating - SGM6sm-250M

Rated service short-circuit breaking capacity (Ics)	: 36 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 50 kA / 36 kA
Tightening torque for terminals	: M8 / 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Ir: (0,8, 0,9, 1,0) x In or (0,7, 0,85, 1,0) x In
Time setting of the inverse time delay release	: Fixed, tripping time at 2 Ir: 30 s - 11 min
Instantaneous release	: Ii: (5, 6, 7, 8, 9, 10) x In

Product rating - SGM6sm-250L

Rated service short-circuit breaking capacity (Ics)	: 25 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 36 kA / 25 kA
Tightening torque for terminals	: M8 / 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Ir: (0,8, 0,9, 1,0) x In or (0,7, 0,85, 1,0) x In
Time setting of the inverse time delay release	: Fixed, tripping time at 2 Ir: 30 s - 11 min
Instantaneous release	: Ii: (5, 6, 7, 8, 9, 10) x In

Product rating - SGM6s-250H

Rated service short-circuit breaking capacity (Ics)	: 50 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 65 kA / 50 kA
Tightening torque for terminals	: M8 / 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Ir: (0,8, 0,9, 1,0) x In or (0,7, 0,85, 1,0) x In
Time setting of the inverse time delay release	: Fixed, tripping time at 2 Ir: 30 s - 11 min
Instantaneous release	: Ii: 10 In

Product rating - SGM6s-250M

Rated service short-circuit breaking capacity (Ics)	: 36 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 50 kA / 36 kA
Tightening torque for terminals	: M8 / 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Ir: (0,8, 0,9, 1,0) x In or (0,7, 0,85, 1,0) x In
Time setting of the inverse time delay release	: Fixed, tripping time at 2 Ir: 30 s - 11 min
Instantaneous release	: Ii: 10 In

Product rating - SGM6s-250L

Rated service short-circuit breaking capacity (Ics)	: 25 kA
Rated ultimate short-circuit breaking capacity (Icu)	: 36 kA / 25 kA
Tightening torque for terminals	: M8 / 6 Nm
Line/load terminal	: Marked
Connection	: Copper conductor with cable lug
Inverse time delay release	: Ir: (0,8, 0,9, 1,0) x In or (0,7, 0,85, 1,0) x In
Time setting of the inverse time delay release	: Fixed, tripping time at 2 Ir: 30 s - 11 min
Instantaneous release	: Ii: 10 In