



Ref. Certif. No.

SE-92905

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product

Residual current operated circuit-breakers with integral overcurrent protection for household and similar uses (RCBOs)

Name and address of the applicant

MAXGE ELECTRIC TECHNOLOGY CO., LTD.
No. 299 EAST CHANGHONG ROAD, WUKANG TOWN,
DEQING COUNTY, ZHEJIANG PROVINCE, P.R.CHINA

Name and address of the manufacturer

Same as applicant

Name and address of the factory

Note: When more than one factory, please report on page 2

Same as applicant

Ratings and principal characteristics

See page 2

Trademark (if any)

Customer's Testing Facility (CTF) Stage used

-

Model / Type Ref.

SGRM, EPRM

Additional information (If necessary may also be reported on page 2)

-

A sample of the product was tested and found to be in conformity with

IEC 61009-1:2010+A1+A2
IEC 61009-2-2:1991

As shown in the Test Report Ref. No. which forms part of this Certificate

180602176SHA-001

This CB Test Certificate is issued by the National Certification Body

Intertek Semko AB
Box 1103
SE-164 22 Kista, Sweden
Int +46 8 750 00 00

Date: 20 December 2018

intertek

Signature:

Henrik Wikström

Ratings and principal characteristics

$U_n = 240V \sim (1P+N)$, 50/60Hz

$I_n = 6, 10, 16, 20, 25, 32, 40A$, B-&C-type

$I_{\Delta n} = 0,01A$ (6-16A), type-A&-AC

$I_{\Delta n} = 0,03, 0,1, 0,3A$ (6-40A), type-A&-AC

$I_{cs} = 7500A$, $I_{cn} = 10000A$, Energy limiting class 3

Date: 20 December 2018

Signature: 